

**Detailed specification for UPS (650VA minimum)**

Description	Minimum Detail Specification	Bidder's Response	
		Yes/No	If "No", Bidders Response
i. Make/Brand: (Should be mentioned by the bidder) ii. Model: (Should be mentioned by the bidder) iii. Country of Origin: (Should be mentioned by the bidder)			
Input Power	180-270 Volts, 50Hz		
Output Power	230 Volts, 50 Hz		
Output Slots	At least two output slots		
Backup Time	7-10 min or above		
Capacity	650 VA minimum		
Transfer Time	0.5ms or less		
Indicator	Audible power failure alarm, separate LED's for A/C power, battery charging, battery backup, low battery alarm (Specify)		
Protection	Over voltage protection, Lightning protection, Short circuit protection, Surge protection		
Battery Type	Sealed & Maintenance free		
Recharge Time	6-8 hours to 90% Capacity		
Cables	One input power cable Two Output Cables		
Warranty	As per Section V SCC clause 28.3 of Bid Sheet.		
Brochures	Brochures for the offered model (only) shall be submitted with the bid.		